The Bhagirathi Co-operative Milk Producers' Union Limited
(A Govt. of West Bengal Project)

CORRIGENDUM

BU/MDO/RIDFXXIX/1113 Date: 03.10.2026

Subject: Corrigendum to Tender No. BU/MDO/RIDFXXIX/1025 dated 16.09.2026 Supply, Installation, Testing & Commissioning of 10 KLPH RO Plant.

The clarifications/revised amendments are as follows:

Sl. No.	Parameters	Existing	Revised/Clarification
1.	RO Membrane Quantity	2 Nos (8")	10 Nos (8") to match membrane housing configuration
2.	CIP Tank Capacity	100 Ltr HDPE	Minimum 500 Ltr HDPE
3.	Feed TDS	Up to 10,000 ppm	Design margin up to 10,000 ppm retained; however, actual feed water TDS is ~700 ppm as per water report.
4.	RO Permeate TDS	<10 ppm (treated water quality table)	Bidders must ensure 10-25 ppm permeate quality.
5.	Pressure Sand Filter (PSF) Size	18" × 64", 2 Nos	48" × 72", 2 Nos
6.	Activated Carbon Filter (ACF) Size	18" × 64", 2 Nos	48" × 72", 2 Nos.
7.	Filter Feed Pump Capacity	2.5 HP, Kirloskar, 1 No	Pump capacity shall be adequate for 20 m^3/hr flow or 10 m^3/hr RO Water at 60ft height. (Make- Kirloskar)

Note

- All other terms and conditions of the tender remain unchanged.
- This corrigendum must be read with the original tender document.
- Bidders are requested to quote strictly as per the revised specifications.

Sd/-
Managing Director
Bhagirathi Cooperative
Milk Producers' Union Limited